

Forecasted values of cross-border transmission capacity for year 2009 Direction – export

PSE – Operator S.A. publishes herewith forecast of cross-border transmission capacity which was calculated with consideration of transmission system security standards and with respect to operating procedure and planning. The forecast has been prepared based on yearly transmission grid maintenance schedule. The estimation is preliminary and will be updated according to monthly maintenance schedules.

Direction PL – DE/CZ/SK (Export)						
	TTC	TRM	NTC**	AAC***	okres	Reason of Congestion (scheduled outage)
1	1500	700	800	0	1/01 - 4/01	
2	1100	700	400	0	5/01 - 16/02	KOP-LIS i BUJ -LIS
3	1500	700	800	0	17/02 - 01/03	
4	1200	700	500	0	2/03 - 8/03	LEM - V.KAP
5	1300	700	600	0	9/03 - 14/03	V.KAP - MUK
6	1600	700	900	0	15/03 - 23/04	
7	1500	700	800	0	24/04 - 26/04	CRN - PAS
8	1000/900*	700	300/200*	0	27/04 - 3/05	DBN - PAS
9	1300/1200*	700	600/500*	0	4/05 -10/05	DBN - ALB
10	1600	700	900	0	11/05 - 17/05	
11	1400	700	700	0	18/05 - 20/05	WIE - NOS; RZE - KRI
12	1500	700	800	0	21/05 - 22/05	WIE - NOS
13	1600	700	900	0	23/05 - 24/05	
14	1200	700	500	0	25/05 - 28/05	LEM - V.KAP
15	1600	700	900	0	29/05 - 7/06	
16	1400/1300*	700	700/600*	0	8/06 - 11/06	KOP - LIS i BUJ - LIS
17	1600	700	900	0	12/06 - 7/07	
18	1400	700	700	0	8/07 - 15/07	KRI - TAW
19	1600	700	900	0	16/07 - 2/08	
20	600	600	0	0	3/08 - 9/08	KRI - LEM t.1 i t.2
21	1400	700	700	0	10/08 - 14/08	LTPM - SPNV
22	1600	700	900	0	15/08 - 20/09	
23	1200/1100*	700	500/400*	0	21/09 - 24/09	NOS - ALB i V.KAP - MUK
24	1200/1100*	700	500/400*	0	25/09	NOS - ALB
25	1600	700	900	0	26/09 - 18/10	
26	1300	700	600	0	19/10 – 23/10	LEM - SPNV
27	1600	700	900	0	24/10 - 22/11	
28	1500	700	800	0	23/11 - 27/11	NOS - VAR
29	1500	700	800	0	28/11 - 31/12	

* at external temperature above 25° C

** PSE- Operator S.A. will offer transmission capacity in coordinated auction accordingly with available capacity and required level of reserves in the power system

*** transmission capacity allocated in yearly coordinated auction

Forecasted values of cross-border transmission capacity for year 2009 Direction – Import

PSE – Operator S.A. publishes herewith forecast of cross-border transmission capacity which was calculated with consideration of transmission system security standards and with respect to operating procedure and planning. The forecast has been prepared based on yearly transmission grid maintenance schedule. The estimation is preliminary and will be updated according to monthly maintenance schedules.

Direction DE/CZ/SK – PL (Import)						
	TTC	TRM	NTC**	AAC***	okres	Reason of Congestion (scheduled outage)
1	700	700	0	0	1/01 - 2/04	
2	700	700	0	0	3/04 - 5/04	MIK - CRN
3	900	700	200	0	6/04 - 13/04	
4	900	700	200	0	14/04 - 17/04	MIK - HAG t. 567
5	900	700	200	0	18/04 - 19/04	
6	900	700	200	0	20/04 - 23/04	MIK - HAG t.568
7	700	700	0	0	24/04 - 26/04	PAS - CRN
8	700	700	0	0	27/04 - 3/05	PAS - DBN
9	900	700	200	0	4/05 - 10/05	
10	700	700	0	0	11/05 - 15/05	MIK-AT1 400/220 kV
11	900	700	200	0	16/05 - 5/07	
12	700	700	0	0	6/07 - 10/07	MIK-AT2 400/220kV
13	900	700	200	0	11/07 - 26/07	
14	700	700	0	0	27/07 - 8/08	MIK - POL t.1
15	900	700	200	0	9/08	
16	700	700	0	0	10/08 - 22/08	MIK - POL t.2
17	900	700	200	0	23/08	
18	700	700	0	0	24/08 - 5/09	MIK - LSN
19	900	700	200	0	6/09 - 22/09	
20	700	700	0	0	23/09 - 25/09	KRA - VIE t. 508
21	900	700	200	0	26/09 - 27/09	
22	700	700	0	0	28/09 - 30/09	KRA - VIE t. 507
23	900	700	200	0	1/10 - 30/11	
24	700	700	0	0	1/12 -31/12	

* at external temperature above 25° C

** PSE- Operator S.A. will offer transmission capacity in coordinated auction accordingly with available capacity and required level of reserves in the power system

*** transmission capacity allocated in yearly coordinated auction